

# Certificate

Page 1

Report No.: 21203488

**License Holder:**  
**Conergy AG**  
Ankelmannsplatz 1  
20537 Hamburg  
Germany

**Product:**  
**PV Modules**  
Types: **E 165P, E 175P**

**Manufacturing Plant:**  
753108  
ScanModule AB

**Basis:**


- TÜV Spec TZE/2.572.09**  
"Safety Class II Test on  
Photovoltaic (PV) Modules"
  
- Factory Inspection**  
To document the consistent quality of  
the product factory inspections are  
performed periodically.

**Remarks:**

The above mentioned PV module may be used in PV plants at a total voltage (maximum system voltage) of up to **1000 VDC**.  
The module types have been developed from the PV module types SCM165/175 (report no.: 21202555).  
Differences: - Name plate label

**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. The certificate is only valid in conjunction with proof of the suitability of the modules in accordance with IEC 61215 (or similar procedure).  
**The certificate has a validity of 5 years counting from the date of issue, provided that the testing basis remains unchanged.**

**Renewable Energies**

Dipl.-Ing. W. Vaaßen

Cologne, 11 November 2004